

RHODE ISLAND GOVERNMENT REGISTER
ONLINE PUBLIC COMMENTS
Date: 02/05/2019

Regulation: 450-RICR-00-00-8

Title: Rhode Island Fire Safety Code Section 8 of the Rhode Island Life Safety Code (450-RICR-00-00-8)

Total Number of Online Comments Received: 1

Comment from: Scott Mooney On 01/03/2019

Per (Add) 12.3.4.3.8 and (Add 13.3.4.8)

Upon the activation of any fire alarm system in any nightclub place of assembly or theater, the fire alarm system shall be interconnected with the building systems so that all emergency lights or other appropriate lighting shall activate and that

all other conflicting sounds and visuals shall cease.

Question; Should there be a comma between the words night club and the words place of assembly (above) since a night club automatically is classified as a place of assembly under the code? There are many different assembly uses that have similar issues with high volume music, visual effects and low lighting. these can drown out and create conflicting visual effects the audible/visable notification creating the same dangerous conditions that you would find in a night club or a theater. If it is not all places of assembly then the phrase place of assembly should be stricken to not create confusion with the acutual intent of these codes.